

S/N: 001065

No.: **ICR Polska/VC/C201001**

**Name and address of Applicant**

GEVORKYAN, s.r.o.  
Továrenská 504, 976 31 Vlkanová, Slovakia

**Name and address of manufacturer:**

GEVORKYAN, s.r.o.  
Továrenská 504, 976 31 Vlkanová, Slovakia

**Product name:**

Reusable mask /  
Maska medyczna wielokrotnego użytku z wymiennymi wkładami filtrującymi

**Product types:**

Smart, Mia, Industry

**Product trademark:**



This document confirms that the product sample meets the requirements of the following standards:

- Related with Directive 93/42/EEC:

EN 14683:2019+AC:2019 (medical mask type II) - for mask with white filters  
- for mask with blue filters

The assessment process has been carried out in accordance with individual rules and conditions agreed with the applicant. Evaluation has been carried out in accordance with:

**Test reports:**

- 84/2020
- 005/2020
- B24046II

**Tests conducted by:**

- VÚTCH-CHEMITEST spol. s r.o.
- STU Bratislava, FCHPT
- HygCen Austria GmbH

- for mask with white filters

- for mask with blue filters

**Issue date:**

12.10.2020

**Expiration date:**

11.10.2025

**Remarks**

This Verification of conformity refers to the above mentioned product and its conformity in regards of above mentioned standard(s) was proven on test sample.

This Verification of conformity was issued on voluntary basis and does not imply meeting all essential requirements, assessment of the series-production or any other restricted Notified Bodies conformity assessment procedure appropriate for the product.



marking remarks:

mark is not sanctioned by the following verification of conformity mark given here as reference, can be only use by the manufacturer after applying all essential requirements from relevant directives

document status can be checked: <https://cert.icrpolska.com/>

Director: Rafał Kalinowski

Warsaw, 12.10.2020

